

Project Name: UNIVERSITY OF CALIFORNIA, MERCED
CPTU TEMPORARY COOLING

Project No.: 907057

ADDENDUM NO. 1
to the
CONTRACT DOCUMENTS
May 28, 2014

- I. Bidder acknowledges that it is the Bidder's responsibility to ascertain whether any Addenda have been issued and if so, to obtain copies of such Addenda. Bidder therefore agrees to be bound by all Addenda that have been issued for this bid.

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents. The following changes, additions, or deletions shall be made to the following documents as indicated and all other Contract Documents shall remain the same.

II. CLARIFICATIONS

- A. PRE-BID QUESTIONS – Questions received from bidders and responses are as follows:
1. Q. Please clarify contractor's scope regarding circuit breaker trip unit monitoring and tie in to existing network. See sheet TC-E-300, key note 4.
 - A. Contractor to jumper cable to the mod bus. Software and programming provided by the University.
 2. Q. Should there be air vents for the stub outs at the utility vault?
 - A. Yes. Contractor is to propose, furnish and install air vents.

V. DRAWINGS

None

VI. ATTACHMENTS

1. Mandatory Job Walk Sign In Sheet 5/28/2014

UNIVERSITY OF CALIFORNIA, MERCED

**By: University of California, Merced
University's Representative**

Fran Telechea
Assistant Director of Construction Administration

End of Addendum No. 1

ADDENDUM NO. 1