

**Project Name:** UNIVERSITY OF CALIFORNIA, MERCED  
GARDEN SUITES HOT WATER PIPE REPAIRS

**Project No.:** UCMFAC-17-1520

**ADDENDUM NO. 2**  
to the  
**CONTRACT DOCUMENTS**  
**April 18, 2017**

- I. Bidder acknowledges that it is the Bidder's responsibility to ascertain whether any Addenda have been issued and if so, to obtain copies of such Addenda. Bidder therefore agrees to be bound by all Addenda that have been issued for this bid.

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents. The following changes, additions, or deletions shall be made to the following documents as indicated and all other Contract Documents shall remain the same.

**II. CLARIFICATIONS**

- A. PRE-BID QUESTIONS – Questions received from bidders and responses are as follows:
1. Q. Who performed the work that has been complete to date?  
A. The work was performed by two contractors, Applegate Drilling Co, Inc. and Artisan Design Group, Inc.
  2. Q. Do you have any information and photos you can provide?  
A. 9 locations were repaired. 8 were excavated to 3'-6" and one was excavated to 10'. Concrete footings were encountered at 2 locations. Attached are photos.
  3. Q. Please clarify testing pressures?  
A. All work shall be tested to 75 psi, not 150 psi as stated in Addendum.

**V. ATTACHMENTS**

1. Photos

**UNIVERSITY OF CALIFORNIA, MERCED**

**By: University of California, Merced**

**End of Addendum No. 2**

ADDENDUM NO. 2







ADDENDUM NO. 2





ADDENDUM NO. 2





ADDENDUM NO. 2







