

**Project Name: UNIVERSITY OF CALIFORNIA, MERCED
SITE DEVELOPMENT AND INFRASTRUCTURE PHASE 4**
Project No.: 906050

ADDENDUM NO. 5
to the
CONTRACT DOCUMENTS
August 24, 2012

- I. Bidder acknowledges that it is the Bidder's responsibility to ascertain whether any Addenda have been issued and if so, to obtain copies of such Addenda. Bidder therefore agrees to be bound by all Addenda that have been issued for this bid.

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents. The following changes, additions, or deletions shall be made to the following documents as indicated and all other Contract Documents shall remain the same.

II. BIDDING/CONTRACT DOCUMENTS AND DIVISION 1 SPECIFICATIONS – VOLUME 1

A. NONE

III. CLARIFICATIONS

A. PRE-BID QUESTIONS

Questions received from bidders and responses are as follows:

1. Q: The specification section does not have a points list or sequence of operations.

A: The required I/O for the RO System is shown on the attached Section 23 3001 Addendum #5. The required I/O for the all VFD units is shown on the specification Section 26 2923 paragraph 2.2.E.5

2. Q. Under civil plans, plan C-402 under Drawing and Scale Orientation there is a cumpas and a black and white line with a 0 on the left end, 250" in the middle, and 500" on the right end. Does this mean that the measurement scale is 1 inch = 500 feet?

A. Civil plans C-401 and C-402 show wrong scales. Replace the scales on C-401 and C-402 to 1"=20'. Civil plans C-401 and C-402 have the same scales as civil plans C-201 and C-202.

IV. SPECIFICATIONS

A. RE-ISSUE THE FOLLOWING SPECIFICATION SECTION

1. SECTION 23 0001 REVERSE OSMOSIS SYSTEM

V. DRAWING SHEETS

1. NONE

UNIVERSITY OF CALIFORNIA, MERCED

**By: University of California, Merced
University's Representative**

Wenbo Yuan
Sr. Project Director

End of Addendum No. 5